

SUMMARY REPORTS FOR MUNICIPALITIES

Report

This report is a summary of water quality information for the Norwood Well Supply System published in accordance with Schedule 22 of Ontario's Drinking-Water Systems Regulation for the reporting period of January 1, 2009 to December 31, 2009. The Norwood Well Supply System is categorized as a Large Municipal Residential Drinking Water System.

This report was prepared by The Ontario Clean Water Agency on behalf of the Corporation of the Township of Asphodel-Norwood.

Who gets a copy of the Report:

- in the case of a drinking-water system owned by a municipality, the members of the municipal council;
- in the case of a drinking-water system owned by a municipal service board established under section 195 of the *Municipal Act, 2001*, the members of the municipal service board; or
- in the case of a drinking-water system owned by a corporation, the board of directors of the corporation.

What must the Report contain?

The report must,

- (a) list the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water licence and any orders applicable to the system that were not met at any time during the period covered by the report; and
- (b) for each requirement referred to in clause (a) that was not met, specify the duration of the failure and the measures that were taken to correct the failure.

The following table lists the requirements that the system failed to meet and the measures taken to correct the failure:

Drinking Water Legislation	List the requirement(s) the system failed to meet	Specify the duration of the failure (i.e. date(s))	Describe the measures taken to correct the failure	Status (complete or outstanding)
Safe Drinking Water Act	NONE			
Ontario Regulations (eg. O. Reg. 170/03, O. Reg. 128/04, O. Reg. 903)	NONE			
System Certificate of Approval No. 6187-7FXKKQ	NONE			
System Permit to Take Water No. 93-P-3023	NONE			
Provincial Officer's Order No.	NONE			

What else must the Report contain?

The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval, drinking water works permit or municipal drinking water licence.

Norwood Well Supply System – 2009 Flow Data				
Month	Total Flow (m ³ /month)	Average Daily Flow (m ³ /day)	Max. Daily Flow (m ³ /day)	CofA Max. Design Capacity Flow Rate (m ³ /day)
January	24,052	776	982	1,965
February	20,941	748	825	1,965
March	23,032	743	820	1,965
April	23,747	792	924	1,965
May	24,024	775	911	1,965
June	25,157	839	966	1,965
July	25,447	821	967	1,965
August	23,165	747	902	1,965
September	22,525	751	921	1,965
October	23,046	743	889	1,965
November	22,162	739	933	1,965
December	21,085	680	794	1,965

The above table shows that there were no exceedances of the quantity of water supplied or of the maximum design rated capacity from the treatment system into the distribution system during the reporting period.

When Does the Report Get Submitted?

If a report is prepared for a system that supplies water to a municipality under the terms of a contract, the owner of the system shall give a copy of the report to the municipality by March 31.